

INSTRUCTIONS FOR EXHIBITORS, SERVICE PROVIDERS AND STAND CONSTRUCTORS

The demonstration of gas-powered devices is subject to notification. The documents have to be uploaded in the AICHEMA Exhibitor Portal at www.achema.de/exhibitorportal by **22 June 2022** at the latest.

As a general rule, all exhaust gases and vapours must be conducted outside by an appropriate exhaust duct. The following provisions shall apply for all devices (exhibits) that are not equipped for the connection of an exhaust duct:

- Gas-powered devices without an exhaust duct cannot be kept in continuous operation.
- These devices may only be operated for the purposes of customer demonstrations.
- The duration of operation must be limited to no more than ten minutes per hour.
- The devices being presented in operation must be positioned and secured such that they pose no danger to people and no objects in the vicinity could catch fire.
- Please note that there must be a fire extinguisher at each stand. The fire extinguishers must have an extinguishing capacity of at least 27A for fire class A or 144B for fire class B and should not be heavier than 12 kg.

In addition the Technical Regulations of AICHEMA 2022 must also be observed, particularly:

- 5.6 Machinery, pressure vessels, exhaust systems
- 5.7 Employment of compressed gases, liquid gases, combustible liquids and hazardous materials

In the event of non-compliance with the aforementioned provisions, the fire protection authorities of the city of Frankfurt am Main (Branddirektion) and DEICHEMA Ausstellungs-GmbH reserve the right to undertake further measures.