

INSTRUCTIONS FOR EXHIBITORS, SERVICE PROVIDERS AND STAND CONSTRUCTORS

We would like to point out once again that all stand construction and decoration materials must be at least B1 in accordance with DIN 4102 or at least class C s2 d2 in accordance with EN 13501-1, i.e. flame-retardant, and must not drip or emit toxic gases. Higher requirements apply as follows:

- In particular, for materials used overhead or for ceiling constructions, the classification is at least C s2 do (non-flammable dripping) according to EN 13501-1.
- For floor coverings the classification is at least Cfl s1.

In individual cases, special requirements may be imposed on load-bearing structural components for safety reasons.

All types of plants as well as deciduous and coniferous trees may only be used **with a moist root ball**.

Artificial plants must be certified as flame-retardant in accordance with DIN 4102, at least class B1, or in accordance with DIN EN 13501-1 at least class C s1 d2, and must not drip when burning or emit toxic gases. A copy of the certificate must be available at the stand.

All materials installed that do not comply with fire protection regulations must be removed and replaced immediately.