



INSTRUCTIONS FOR EXHIBITORS, SERVICE PROVIDERS AND STAND CONSTRUCTORS

At least one fire extinguisher (ABC 6 kg) and one fire blanket (complying with DIN EN 1869 standard) should be kept available at all times.

Furthermore, flammable materials may not be kept in the immediate vicinity of the exhibit.

All floors and rear/side walls in the direct vicinity of the exhibit must be made of non-flammable materials.

Exhibits featuring open flames may not be placed directly at the edge of stands.

Please consult the DECHEMA Ausstellungs-GmbH with regard to the required positioning within the stand area.

Use of flammable liquids

When using flammable liquids, please be sure to also refer to item 5.7.2 of the Technical Regulations. The storage and use of flammable liquids (hazard statement H224, H225 or H226 according to CLP Regulation, see also TRGS 510) in the exhibition halls and on the exhibition grounds is prohibited without written authorization. It is possible to obtain authorization for the storage and use of flammable liquids for the operation or demonstration of exhibits. The corresponding application must be submitted to DECHEMA Ausstellungs-GmbH together with the safety data sheet by **14 April 2027**.

Daily requirement of flammable liquids

Only the daily requirement of flammable liquids may be stored at the stand for the purposes of operation and demonstration. The specific quantities involved must be specified in the application for approval.

Container and storage location

The daily requirement of flammable liquid must be neatly stored in closed, shatterproof containers and protected against unauthorized access. The storage containers are to be stored in non-flammable collection containers. Smoking is prohibited at the storage site; open fires and other possible sources of ignition must be kept away. Suitable "No Smoking" signs shall be posted. Suitable manual fire extinguishers shall be on hand at all times.

Empty containers that have contained flammable liquids shall not be kept or stored on stands or in exhibition halls.

For suitable storage facility please contact Messe Frankfurt's Logistics Services logistics@messefrankfurt.com. They will provide appropriate storage space at exhibitor's expense.



Please upload at
www.achema.de/exhibitorportal

Login see stand confirmation

Hall _____ Stand _____

Company _____

Deadline 14 April 2027

For inquiries: safety@dechema.de

Phone +49 6172 89938-655

1. Type of liquid:

2. Purpose:

3. Where will the containers be kept (exact position on the stand)?

The exhibitor must label the container position with a warning sign „flame hazard“ according to ASR A1.3 and DIN EN ISO 7010 being visible from outside.

4. Amount required per day: _____ piece _____ Content in kg or l

5. Are vapour/air mixtures or waste gases produced during processing?

no yes _____ daily filling

Supplies of combustible liquids sufficient for one day's operation and/or demonstration only may be stored on stands. Empty containers shall not be kept or stored on the stand.

For suitable storage facility please contact Messe Frankfurt's Logistics Service, logistics@messefrankfurt.com. They will provide appropriate storage space at exhibitor's expense.

The stand was designed in compliance with the Technical Regulations (5.7.2).

Person to contact _____

E-mail _____

Phone _____

Mobile _____

Place / Date

Company stamp / Signature